

<b>Table 3.3.5-2</b>	
<b>Interconnect Cable System Distance From The Monomoy Shoals Alternative Site To The Barnstable Substation</b>	
<b>115 kV Cable Length</b>	<b>Total Distance</b>
Electric Service Platform to Barnstable Substation	29.8 miles
Upland cable	5.9 miles
Submarine cable	23.9 miles
Submarine cable Outside of 3-mile limit	2.9 miles
Submarine cable Inside of 3-mile limit	21.0 miles

<b>Table 3.3.6-1</b>				
<b>Examples of WTG Grid Spacing for Offshore Wind Parks</b>				
<b>Wind Park/Location</b>	<b>Spacing (rotor diameter)</b>			<b>Ratio</b>
Horns Rev/Denmark	7.0	x	7.0	1.0
Nysted/Denmark	10.4	x	5.8	1.8
Kentish Flats/Denmark	7.8	x	7.8	1.0
Barrow/United Kingdom	8.3	x	5.6	1.5
Burbo/United Kingdom	6.7	x	5.0	1.4
North Hoyle/United Kingdom	10.0	x	4.4	2.3
<b>Average</b>	<b>8.4</b>	<b>x</b>	<b>5.9</b>	<b>1.5</b>
<b>Cape Wind</b>	<b>9.0</b>	<b>x</b>	<b>5.7</b>	<b>1.6</b>